

DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur
dwtlgsp1@gmail.com



TC-14032

TEST REPORT

Name & Address of Customer : Kids International School Jail Road, Dharochack Gurdaspur	Customer Reference No. : 5790/461/2025-26 Dated : 13/05/2025 Sample Submitted by : Tijinder(Principal) Date of Sample Receipt : 13/05/2025 Analysis Starting Date : 13/05/2025 Analysis completion Date : 14/05/2025
Discipline : Chemical Testing ULR No.: TC140322500000281F Test Report No.: DWTLGSP/2526/00093 Registration no.: DWTLGSP/REG2526/00161 Collection Point: Private Submersible Scheme/Source: Not Mentioned(Not Mentioned)	Group: Water Sample Type : Water Date of Issue : 15/05/2025 Condition of Sample : Unsealed Quantity/Type of Bottle: 1000 ml / Plastic Bottles Location/Depth : Kids International School Jail Road Dharochack Gurdaspur / NA
Village : Dharo Chack Block: Gurdaspur Latitude : Not Mentioned	Habitation : Dharo Chack District : Gurdaspur Longitude: Not Mentioned

As per IS-10500:2012 (2nd Rev.)

Sr. No	Parameter	Result	Acceptable Limit	Permissible Limit	Unit	Reference Method :
1	pH	5.8@25°C	6.5-8.5	No Relaxation		IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025 (Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable		IS 3025 (Part 5-2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable		IS 3025 (Part 8-2023)
5	TDS	50	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL@25°C	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO3)	20	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO3)	24	200	600	mg/l	IS 3025 (Part 21-2009)(RA 2023) EDTA Method
9	Calcium(Ca)	6.41	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	1.94	30	100	mg/l	APHA (21th Ed 2023) Method 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	9.99	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially
3. This report is not to be reproduce wholly or in part and can't be used as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND = Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit: 50 ±20%

Reviewed and Approved By

Mr. Pankaj Kumar
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Gurdaspur

End of the Test Report

DISTRICT WATER TESTING LABORATORY, GURDASPUR

District Water Testing Laboratory, Jewanwal Babri, Gurdaspur
dwtlgsp1@gmail.com

To,

Kids International School
Jail Road Dharochack Gurdaspur

No.: DWTLGSP/2526/00093 Dated : 15/05/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. 5790/461/2025-26 Dated: 13/05/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 13/05/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Gurdaspur

D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Gurdaspur